




Firestop Collars

PFC Corofil Firestop Collars provide a simple and effective method of firestopping plastic pipework where it passes through compartment walls and floors.

Tested to BS476 Part 20, Firestop Collars will provide up to 4 hours' fire protection.

- Simple to install
- Water resistant
- Maintenance free
- Available to suit pipe sizes ranging from 55 to 355mm O.D.



PFC Corofil Firestop Collars

Description

PFC Corofil Firestop Collars consist of a powder coated steel sleeve containing a flexible graphite based intumescent liner manufactured to suit the pipework to be firestopped. Integral toggles are opened up and the collar is simply fitted around the plastic pipe. The toggles are closed and the collar is pushed flush to the surface of the wall or underside of floor. The collar is then securely fastened to the structure by means of fire resistant fixings threaded through fixing tabs. Any gaps of up to 25mm wide around the pipework should be filled with PFC Corofil Acoustic Intumescent Sealant. For gaps greater than 25mm wide PFC Corofil Firestop Compound can be used.

Under fire conditions the intumescent material swells filling the void left by the burnt out plastic.

NSPlus

CI/SfB


(59) | 1 | (K2)

August 2005

PFC COROFIL Firestop Products, Davis Road, Chessington, Surrey KT9 1TU

Tel: +44 (0) 208 391 0533 Fax: +44 (0) 208 391 2723 E-mail: sales@pfc-corofil.com

www.pfc-corofil.com



PFC Corofil Firestop Collars fixed to both sides of

Fire Rating

Outside diameter of Pipework	Fire Rating in hours
55 - 250mm	2 or 4
275 - 315mm	3
330 - 355mm	1

Suitable for sealing UPVC, Polypropylene, HDPE and ABS plastic

Specification

Install PFC Firestop Collars to provide up to 1,2,3 or 4 hours' fire protection to all plastic pipework. Installation to be fully in accordance with manufacturer's instructions. See below for contact details.

To Order

Contact our technical sales office (Tel: +44 (0) 208 391 0533) with the following information:

- Pipework diameter
- Fire rating
- Quantity

Technical Information

For further information relating to the installation and Health & Safety, please refer to the Firestop Collar installation instructions.